SIEMENS

Data sheet

3UG4616-1CR20



Digital monitoring relay for 3-phase voltage with N-conductor Phase sequence can be activated Phase failure 3 x 90 to 400 V 50 to 60 Hz AC Undervoltage and overvoltage 90-400 V Hysteresis 1-20 V 0-20 s each for Umin and Umax 1 CO for Umin 1 CO for Umax screw terminal Successor product for 3UG3042-1BP50

| Figuresimilar |
|---------------|
|---------------|

| product brand name | SIRIUS | | |
|--|---|--|--|
| product designation | Network monitoring relay with digital setting | | |
| design of the product | 5 functions | | |
| product type designation | 3UG4 | | |
| General technical data | | | |
| product function | Phase monitoring relay | | |
| display version LED | No | | |
| design of the display | LCD | | |
| insulation voltage for overvoltage category III according to IEC 60664 | | | |
| with degree of pollution 3 rated value | 690 V | | |
| degree of pollution | 3 | | |
| type of voltage | | | |
| for monitoring | AC | | |
| of the control supply voltage | AC | | |
| surge voltage resistance rated value | 6 kV | | |
| protection class IP | IP20 | | |
| shock resistance according to IEC 60068-2-27 | sinusoidal half-wave 15g / 11 ms | | |
| vibration resistance according to IEC 60068-2-6 | 1 6 Hz: 15 mm, 6 500 Hz: 2g | | |
| mechanical service life (switching cycles) typical | 10 000 000 | | |
| electrical endurance (switching cycles) at AC-15 at 230 V typical | 100 000 | | |
| thermal current of the switching element with contacts maximum | 5 A | | |
| reference code according to IEC 81346-2 | К | | |
| relative repeat accuracy | 1 % | | |
| Substance Prohibitance (Date) | 05/01/2012 | | |
| Product Function | | | |
| product function | | | |
| undervoltage detection | Yes | | |
| overvoltage detection | Yes | | |
| phase sequence recognition | Yes | | |
| phase failure detection | Yes | | |
| asymmetry detection | Yes | | |
| overvoltage detection 3 phase | Yes | | |
| undervoltage detection 3 phases | Yes | | |
| voltage window recognition 3 phase | Yes | | |
| adjustable open/closed-circuit current principle | Yes | | |
| ● auto-RESET | Yes | | |

| Control circuit/ Control | |
|---|---|
| control supply voltage at AC | |
| at 50 Hz rated value | 90 400 V |
| at 60 Hz rated value | 90 400 V |
| operating range factor control supply voltage rated | 50 1 00 V |
| value at AC at 50 Hz | |
| initial value | 1 |
| • full-scale value | 1 |
| operating range factor control supply voltage rated | |
| value at AC at 60 Hz | |
| initial value | 1 |
| full-scale value | 1 |
| Measuring circuit | |
| measurable voltage at AC | 400 90 V |
| adjustable response delay time | |
| with lower or upper limit violation | 0.1 20 s |
| accuracy of digital display | +/-1 digit |
| Precision | |
| relative metering precision | 5 % |
| Auxiliary circuit | |
| number of NC contacts delayed switching | 0 |
| number of NO contacts delayed switching | 0 |
| number of CO contacts delayed switching | 2 |
| operating frequency with 3RT2 contactor maximum | 5 000 1/h |
| Main circuit | |
| number of poles for main current circuit | 3 |
| ampacity of the output relay at AC-15 | |
| • at 250 V at 50/60 Hz | 3 A |
| • at 400 V at 50/60 Hz | 3 A |
| ampacity of the output relay at DC-13 | |
| • at 24 V | 1 A |
| • at 125 V | 0.2 A |
| • at 250 V | 0.1 A |
| operational current at 17 V minimum | 5 mA |
| continuous current of the DIAZED fuse link of the | 4 A |
| output relay | |
| Electromagnetic compatibility | |
| conducted interference | 0.197 |
| • due to burst according to IEC 61000-4-4 | 2 kV |
| due to conductor-earth surge according to IEC 61000-4-5 | 2 kV |
| due to conductor-conductor surge according to IEC | 1 kV |
| 61000-4-5 | |
| field-based interference according to IEC 61000-4-3 | 10 V/m |
| electrostatic discharge according to IEC 61000-4-2 | 6 kV contact discharge / 8 kV air discharge |
| Galvanic isolation | |
| galvanic isolation | |
| between input and output | Yes |
| between the outputs | Yes |
| between the voltage supply and other circuits | Yes |
| Connections/ Terminals | |
| product component removable terminal for auxiliary and control circuit | Yes |
| type of electrical connection | screw-type terminals |
| type of connectable conductor cross-sections | |
| • solid | 1x (0.5 4 mm2), 2x (0.5 2.5 mm2) |
| finely stranded with core end processing | 1x (0.5 2.5 mm2), 2x (0.5 1.5 mm2) |
| at AWG cables solid | 2x (20 14) |
| | |
| at AWG cables stranded connectable conductor cross-section | 2x (20 14) |

| • solid | 0.5 4 mm² | | |
|--|-------------------------|---------------------|---------------------|
| finely stranded with core end processing | 0.5 2.5 mm ² | | |
| AWG number as coded connectable conductor c | | | |
| section | | | |
| • solid | 20 14 | | |
| stranded | 20 14 | | |
| tightening torque with screw-type terminals | 0.8 1.2 N·m | | |
| Installation/ mounting/ dimensions | | | |
| mounting position | any | | |
| fastening method | snap-on mounting | | |
| height | 102 mm | | |
| width | 22.5 mm | | |
| depth | 91 mm | | |
| required spacing | | | |
| with side-by-side mounting | | | |
| — forwards | 0 mm | | |
| — backwards | 0 mm | | |
| — upwards | 0 mm | | |
| — downwards | 0 mm | | |
| — at the side | 0 mm | | |
| for grounded parts | | | |
| — forwards | 0 mm | | |
| — backwards | 0 mm | | |
| — upwards | 0 mm | | |
| — at the side | 0 mm | | |
| — downwards | 0 mm | | |
| for live parts | | | |
| — forwards | 0 mm | | |
| — backwards | 0 mm | | |
| — upwards | 0 mm | | |
| — downwards | 0 mm | | |
| — at the side | 0 mm | | |
| Ambient conditions | | | |
| installation altitude at height above sea level maximu | m 2 000 m | | |
| ambient temperature | | | |
| during operation | -25 +60 °C | | |
| during storage | -40 +85 °C | | |
| during transport | -40 +85 °C | | |
| Certificates/ approvals | | | |
| General Product Approval | | EMC | Declaration of |
| Contra i roddor Approva | | Lino | Conformity |
| <u>Confirmation</u> | 💭 гпг | A | ~ ~ |
| (\mathbf{m}) | (ŸL) FHI | / (A) | (E |
| | | RCM | EG-Konf. |
| | | | |
| | | | |
| Test Certificates Marin | e / Shipping | other | Railway |
| | 6 | | . tanifuj |
| Type Test Certific- Special Test Certific- | L L | Confirmation | Vibration and Shock |
| | Lou refe | | |
| ates/Test Report ate | Kegister í ì | | |
| ates/rest Report ate | | | |
| ates/rest Report ate | | | |
| ates/lest Report ate | | | |
| ates/rest Report ate | | | |
| ates/Test Report ate | | | |
| Further information Information- and Downloadcenter (Catalogs, Brod | URS ENVILOSMON | | |
| Further information Information- and Downloadcenter (Catalogs, Broo https://www.siemens.com/ic10 | URS ENVILOSMON | | |
| Further information Information- and Downloadcenter (Catalogs, Brod | LRS EXAMPLEMENT | | |

Cax online generator http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UG4616-1CR20 Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3UG4616-1CR20 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UG4616-1CR20&lang=en Characteristic: Derating https://support.industry.siemens.com/cs/ww/en/ps/3UG4616-1CR20/manual

last modified:

12/18/2020 🖸